Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM986

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	RAMIREZ, DAYTON
Phone #	
Mailing Address	S12748 COUNTY LINE RD
City	LONE ROCK
State	WI
Zip Code	53556
County	Sauk
Co. Permit #	
Notification #	10249167101
Completed	04-29-2026
Well Constructor (Business Name)	SAM'S WELL DRILLING
Lic. #	370
Facility ID # (Public Wells)	
Address	150 RANDOLPH STREET RANDOLPH WI 53956
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1.2

1. Well Location

Town of SPRING GREEN	S12584
Street Address or Road Name and Number	
TIMBER TRAIL	
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.17728 °N -90.11038 °W
Method Code	GPS008
SW SW or Govt Lot #	
Section	11
Township	8 N
Range	3 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	102

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	X	Y		X-LENSED/STREAKED/LAYERED Y-SAND & GRAVEL	Surface	80
	A	S		A-COARSE S-SAND	80	97
	A	Y		A-COARSE Y-SAND & GRAVEL	97	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD, BLK, PIPE, .280 WALL, P.E., A53B, KUMAKANG	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	#15 SLOTTED STAINLESS STEEL TELESCOPING SCREEN W/ K-PACKER	97	102

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 60 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JVG	6026	04-30-2026
Drill Rig Operator	Lic or Reg #	Date Signed
KB	7372	04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED