Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM987

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: UNBEHAUN, DAVE	Phone #
Mailing Address: 27432 COUNTY HIGHWAY O	
City: RICHLAND CENTER	State: WI / Zip Code: 53581
County: Richland	Co. Permit #:
Notification #: 10234018804	Completed: 04-29-2026
Well Constructor (Business Name): SAM'S WELL DRILLING	Lic. #: 370
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 150 RANDOLPH STREET, RANDOLPH WI 53956	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of RICHLAND	Fire # (if avail.): 27384
Street Address or Road Name and Number: SR 14	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 43.29545 °N -90.32415 °W	Method Code: GPS008
SE SW or Govt Lot #:	Section: 36 / Township: 10 N / Range: 1 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	150

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	X	S	M	X-LENSED/STREAKED/LAYERED S-SAND M-SILTY	Surface	90
		X		X-SAND & CLAY	90	125
	S	N		S-SOFT/LOOSE N-SANDSTONE	125	130
	X	N		X-LENSED/STREAKED/LAYERED N-SANDSTONE	130	150

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD, BLK, PIPE, .280 WALL, P.E., A53B, KUMAKANG	Surface	131
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JVG	6026	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KB	7372	04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED