

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM989		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ERNSTMEYER, MICHAEL						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 58 MEME LN						Town of EXCELSIOR						E7440	
City REEDSBURG						State WI		Zip Code 53959				Street Address or Road Name and Number	
County Sauk						Co. Permit #		Notification # 10204933501				Completed 04-21-2026	
Well Constructor (Business Name) MCAFEE WELL DRLG & PUMP SERV INC						Lic. # 6829		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.53829 °N -89.94967 °W	
Address PO BOX 106 LA VALLE WI 53941						Well Plan Approval #		NE NW		Section 7		Township 12 N	
						Approval Date (mm-dd-yyyy)		Range 5 E		2. Well Type New Well		of previous unique well #	
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled					
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				8. Geology		
8.5 Surface 40			No Rotary - Mud Circulation No				T Q S				Type, Caving/Noncaving, Color, Hardness, etc... T-TAN/BROWN Q-CAVING S-SAND		
6 40 93			No Rotary - Air No				I M N				8 30		
			No Rotary - Air & Foam No				T M N				30 93		
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			Yes Cable-tool Bit 8.5in. dia... No										
			No Dual Rotary No										
			Yes Temp. Outer Casing 8.5in. dia										
			Yes Removed? 8depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		USA PLAIN END WELDED JOINT ASTM A53B 6.625 X 280 EL 21 DRIVESHOE INSTALLED				Surface		40		34 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										24 in. above grade			
7. Grout or Other Sealing Material										10. Pump Test			
Method TREMIE PIPE - PUMPED										Pumping level 48 ft. below surface			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Pumping at 10 GP M for 1 Hrs.			
NEAT CEMENT GROUT		Surface		40		12 S				Pumping Method ? Other			
12. Notified Owner of need to fill & seal ? No										13. Constructor / Supervisory Driller			
Filled & Sealed Well(s) as needed? No										Lic #		Date Signed	
										TM		6112	
										Drill Rig Operator		Lic or Reg #	
												Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	80	POWTS dispersal component (soil absorption unit or mound)	>	80

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED