Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM989

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	ERNSTMEYER, MICHAEL
Phone #	
Mailing Address	58 MEME LN
City	REEDSBURG
State	WI
Zip Code	53959
County	Sauk
Co. Permit #	
Notification #	10204933501
Completed	04-21-2026
Well Constructor (Business Name)	MCAFEE WELL DRLG & PUMP SERV INC
Lic. #	6829
Facility ID # (Public Wells)	
Address	PO BOX 106 LA VALLE WI 53941
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.7

1. Well Location

Fire # (if avail.)	E7440
Town of	EXCELSIOR
Street Address or Road Name and Number	FAIRWAY CT REEDSBURG, WI 53959
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.53829 °N -89.94967 °W
Method Code	SCR002
NE NW or Govt Lot #	
Section	7
Township	12 N
Range	5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	40
6	40	93

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 8.5in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8.5in. dia	
Yes	Removed? 8depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	8
I	M	N		I-WHITE M-MEDIUM N-SANDSTONE	8	30
T	M	N		T-TAN/BROWN M-MEDIUM N-SANDSTONE	30	93

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	USA PLAIN END WELDED JOINT ASTM A53B 6.625 X 280 EL 21 DRIVESHOE INSTALLED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 48 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Other

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	12 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM	6112	04-30-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	80	POWTS dispersal component (soil absorption unit or mound)	>	80

Comment:

Created On: 04-30-2026 Updated On: 10-15-2026 Review Status: APPROVED