

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM999		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GEIPEL, JERRY					Phone # (262)617-8298		1. Well Location				Fire # (if avail.) 906			
Mailing Address 729 WOODTHRUSH LN							Town of THREE LAKES							
City COLGATE					State WI		Zip Code 53017							
County Oneida		Co. Permit #		Notification # 10167709102		Completed 04-29-2026		Subdivision Name				Lot # Block #		
Well Constructor (Business Name) WRANIK, THOMAS F					Lic. # 70		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8083 °N -89.1042 °W		Method Code SCR002	
Address PO BOX 1266 W620 W PINE ST EAGLE RIVER WI 54521-1266					Well Plan Approval #		SE NW		Section 3		Township 38 N		Range 11 E	
							or Govt Lot #							
Hicap Permanent Well #					Common Well #		Specific Capacity 0.2				2. Well Type New Well			
Heat Exchange ___ # of drillholes					Hicap Well ? No		of previous unique well #				constructed in			
Private, potable					Hicap Property ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes					Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		77		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
G		S		S-SAND		Surface		25						
G		G		G-GRAY G-GRAVEL/STONES		25		45						
G		Y		G-GRAY Y-SAND & GRAVEL		45		72						
T		Y		T-TAN/BROWN Y-SAND & GRAVEL		72		77						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		A53BWELDED WHEATLAND 18.97LB SEC 40X20				Surface		74						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		TEL, JOHNSON SS #10				74		77						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
GRANULAR BENTONITE		Surface		6		1 S								
9. Static Water Level														
6 ft. below ground surface														
10. Pump Test														
Pumping level 65 ft. below surface														
Pumping at 10 GP M for 2 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller														
Lic #		Date Signed												
TW		70		04-30-2026										
Drill Rig Operator		Lic or Reg #		Date Signed										
PN		7304		04-30-2026										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		40	POWTS holding component (also known as holding tank)		30

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED