Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM999

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEIPEL, JERRY	Phone #: (262)617-8298
Mailing Address: 729 WOODTHRUSH LN	
City: COLGATE	State: WI — Zip Code: 53017
County: Oneida	Co. Permit #:
Notification #: 10167709102	Completed: 04-29-2026
Well Constructor (Business Name): WRANIK, THOMAS F	Lic. #: 70
Facility ID # (Public Wells):	
Address: PO BOX 1266 W620 W PINE ST EAGLE RIVER WI 54521-1266	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Town of THREE LAKES	Fire # (if avail.): 906
Street Address or Road Name and Number: OLSON RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8083 °N -89.1042 °W	Method Code: SCR002
SE NW or Govt Lot #:	Section: 3 — Township: 38 N — Range: 11 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	77

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	25
G		G		G-GRAY G-GRAVEL/STONES	25	45
G		Y		G-GRAY Y-SAND & GRAVEL	45	72
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	72	77

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53BWELDED WHEATLAND 18.97LB SEC 40X20	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	TEL, JOHNSON SS #10	74	77

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	6	1 S

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	70	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
PN	7304	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		40	POWTS holding component (also known as holding tank)		30

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED