# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACN001

**Drinking Water and Groundwater - DG/5**
**Department of Natural Resources, Box 7921**
**Madison WI 53707**
Form 3300-077A

| | |
|---|---|
| Property Owner: KUST, JASON & JENEECE | Phone #: (920)660-0865 |
| Mailing Address: N133 LAWN RD | |
| City: SEYMOUR | State: WI — Zip Code: 54165 |
| County: Shawano | Co. Permit #: — Notification #: — Completed: 04-28-2026 |
| Well Constructor (Business Name): HINTZKE WELL DRILLING INC | Lic. #: 267 — Facility ID # (Public Wells): |
| Address: N5072 HINTZKE RD, NEW LONDON WI 54961-9802 | Well Plan Approval #: 0000 — Approval Date (mm-dd-yyyy): |
| Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1 | |

**1. Well Location**

| | |
|---|---|
| Town of LESSOR | Fire # (if avail.): N133 |
| Street Address or Road Name and Number: LAWN RD | |
| Subdivision Name: — Lot #: — Block #: — | |
| Latitude / Longitude in Decimal Degree (DD): 44.5893 °N -88.3668 °W | Method Code: GPS008 |
| SE SE or Govt Lot #: — Section: 36 — Township: 25 N — Range: 17 E | |

**2. Well Type** Replacement
of previous unique well #: ABT371 constructed in: 2024
Reason for replaced or reconstructed well ?: WELD BROKEN
Construction Type: Drilled

**3. Well serves** 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 8.75 | Surface | 59 |
| 6 | 59 | 82 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| Yes | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | Yes |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| T | | Y | | T-TAN/BROWN Y-SAND & GRAVEL | Surface | 59 |
| T | | L | | T-TAN/BROWN L-LIMESTONE/DOLOMITE | 59 | 82 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | US WHEATLAND PE 280 WALL A53 WELD | Surface | 61 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**7. Grout or Other Sealing Material**
Method TREMIE PIPE - PUMPED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| HIGH SOLIDS BENTONITE | Surface | 59 | 6 S |

**9. Static Water Level**
20 ft. below ground surface

**10. Pump Test**
Pumping level 40 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Airlift

**11. Well Is**
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ? Yes
WELL WAS FILLED AND SEALED AT TIME OF HOOK UP

Filled & Sealed Well(s) as needed? Yes
WELL WAS FILLED AND SEALED 4/28/2026

| 13. Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| JCH | 6935 | 04-30-2026 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| GEV | 9482 | 04-30-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS treatment component (septic tanks, aerobic treatment units or filters) | | 55 | POWTS dispersal component (soil absorption unit or mound) | | 60 |

Comment: WELL NOTIFICATION NUMBER 10247103701

Created On: 04-30-2026 Updated On: 05-13-2026 Review Status: APPROVED