

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN001		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KUST, JASON & JENEECE				Phone # (920)660-0865		1. Well Location				Fire # (if avail.)	
Mailing Address N133 LAWN RD						Town of LESSOR				N133	
City SEYMOUR				State WI Zip Code 54165		Street Address or Road Name and Number LAWN RD					
County Shawano		Co. Permit #		Notification #		Completed 04-28-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HINTZKE WELL DRILLING INC				Lic. # 267		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.5893 °N -88.3668 °W		Method Code GPS008	
Address N5072 HINTZKE RD NEW LONDON WI 54961-9802				Well Plan Approval # 0000		Approval Date (mm-dd-yyyy)		SE SE Section Township Range or Govt Lot # 36 25 N 17 E			
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type Replacement of previous unique well # ABT371 constructed in 2024 Reason for replaced or reconstructed well ? WELD BROKEN					
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
8.75		Surface		59		Yes Rotary - Mud Circulation			No		
6		59		82		No Rotary - Air			Yes		
						No Rotary - Air & Foam			No		
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...			No		
						No Dual Rotary			No		
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	Y	T-TAN/BROWN Y-SAND & GRAVEL				Surface		59			
T	L	T-TAN/BROWN L- LIMESTONE/DOLOMITE				59		82			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		US WHEATLAND PE 280 WALL A53 WELD				Surface		61			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
HIGH SOLIDS BENTONITE		Surface		59		6 S					
9. Static Water Level											
20 ft. below ground surface											
10. Pump Test											
Pumping level 40 ft. below surface											
Pumping at 20 GP M for 2 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
24 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
WELL WAS FILLED AND SEALED AT TIME OF HOOK UP											
Filled & Sealed Well(s) as needed? Yes											
WELL WAS FILLED AND SEALED 4/28/2026											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
JCH		6935		04-30-2026							
Drill Rig Operator											
Lic or Reg #		Date Signed									
GEV		9482		04-30-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		55	POWTS dispersal component (soil absorption unit or mound)		60

Comment: WELL NOTIFICATION NUMBER 10247103701**Created On:** 04-30-2026**Updated On:** 05-13-2026**Review Status:** APPROVED