# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACN002

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: KSS & COMPANY, LLC | Phone #: (608)235-5691 |
| Mailing Address: PO BOX 178 | |
| City: DEFOREST | State: WI — Zip Code: 53532 |
| County: Vilas | Co. Permit #: |
| Notification #: 10168358901 | Completed: 04-30-2026 |
| Well Constructor (Business Name): WRANIK, THOMAS F | Lic. #: 70 |
| Facility ID # (Public Wells): | |
| Address: PO BOX 1266 W620 W PINE ST<br>EAGLE RIVER WI 54521-1266 | |
| Well Plan Approval #: | |
| Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: |
| Specific Capacity: 1.5 | |

**1. Well Location**

| | |
|---|---|
| Town of WASHINGTON | Fire # (if avail.): 3624 |
| Street Address or Road Name and Number: TOWN LINE ROAD | |
| Subdivision Name: | Lot #: — Block #: |
| Latitude / Longitude in Decimal Degree (DD): 45.9186 °N -89.1828 °W | Method Code: SCR002 |

| NW | SE | Section | Township | Range |
|---|---|---|---|---|
| or Govt Lot # | | 25 | 40 N | 10 E |

**2. Well Type** New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

**3. Well serves** 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 40 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| Yes | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| Yes | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| | | S | | S-SAND | Surface | 10 |
| | | C | | C-CLAY | 10 | 17 |
| | A | S | | A-COARSE S-SAND | 17 | 40 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | A53BWELDED WHEATLAND 18.97LB SEC 40X20 | Surface | 37 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 5 | TEL, JOHNSON SS #10 | 37 | 40 |

**9. Static Water Level**

15 ft. below ground surface

**10. Pump Test**

Pumping level 25 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

**11. Well Is**

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | 15 | 1.5 S |

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| TW | 70 | 04-30-2026 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| PN | 7304 | 04-30-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 100 | Septic or Holding, or POWTS Tank | | 90 |

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED