

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN002		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KSS & COMPANY, LLC						Phone # (608)235-5691		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 178						Town of WASHINGTON						3624					
City DEFOREST						State WI		Zip Code 53532				Street Address or Road Name and Number TOWN LINE ROAD					
County Vilas		Co. Permit #		Notification # 10168358901		Completed 04-30-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WRANIK, THOMAS F				Lic. # 70		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.9186 °N -89.1828 °W				Method Code SCR002			
Address PO BOX 1266 W620 W PINE ST EAGLE RIVER WI 54521-1266				Well Plan Approval #		NW SE		Section 25		Township 40 N		Range 10 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		2. Well Type New Well						of previous unique well # constructed in					
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		40		No Rotary - Mud Circulation		No		S		S-SAND		Surface		10	
						Yes Rotary - Air		No		C		C-CLAY		10		17	
						No Rotary - Air & Foam		No		A S		A-COARSE S-SAND		17		40	
						Yes Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface		12 in. above grade					
6		A53BWELDED WHEATLAND 18.97LB SEC 40X20				Surface		37		10. Pump Test		Developed ? Yes					
										Pumping level 25 ft. below surface		Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 1 Hrs.		Capped ? Yes					
5		TEL, JOHNSON SS #10				37		40		Pumping Method ? Test Pump							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method MOUNDED												Filled & Sealed Well(s) as needed? No					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE		Surface		15		1.5 S											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												TW		70		04-30-2026	
												Drill Rig Operator		Lic or Reg #		Date Signed	
												PN		7304		04-30-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		90

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED