

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN004		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KATELYN HINES						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W5251 KAPHAEM RD						Town of BRADLEY						W5251	
City TOMAHAWK						State WI		Zip Code 54487				Street Address or Road Name and Number KAPHAEM RD	
County Lincoln		Co. Permit # 1		Notification # 10226647602		Completed 04-17-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) NEHLS & WEBSTER WELL DRILLING				Lic. # 6076		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.45161 °N -89.68978 °W		Method Code SCR002	
Address 1901 APACHE LN RHINELANDER WI 54501				Well Plan Approval #		NW NW		Section 12		Township 34 N		Range 6 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled			
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		49		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
Y		Y-SAND & GRAVEL						Surface		28			
Z		Z-CLAY & GRAVEL						28		45			
Y		Y-SAND & GRAVEL						45		49			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		MARIUCCI PE 18.97 A53				Surface		49					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface		25		2 S					
9. Static Water Level													
21 ft. below ground surface													
10. Pump Test													
Pumping level 43 ft. below surface													
Pumping at 10 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
16 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
PW				156				04-30-2026					
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED