Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN006

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, BILL	Phone #: (920)819-4988
Mailing Address: P.O. BOX 430	
City: BAILEYS HARBOR	State: WI — Zip Code: 54202
County: Door	Co. Permit #:
Notification #: 10239343001	Completed: 04-28-2026
Well Constructor (Business Name): WESLOW WATER SYSTEMS INC	Lic. #: 6400
Facility ID # (Public Wells):	
Address: 1710 FLOWING WELLS CT SUAMICO WI 54173	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of GIBRALTAR	Fire # (if avail.): 8518
Street Address or Road Name and Number: CR-A	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0846 °N -87.193 °W	Method Code: GPS008
SW SW or Govt Lot #	Section: 11 — Township: 30 N — Range: 27 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: 4" WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
12	Surface	29
8	29	170
6	170	202

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 29depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	X	X	G	X-LENSED/STREAKED/LAYERED X-SAND & CLAY G-W/GRAVEL/STONES	Surface	24
		Z		Z-CLAY & GRAVEL	24	29
		L		L-LIMESTONE/DOLOMITE	29	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A53 18.97# NUCOR WELDED	Surface	170
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	170	35 S

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
A.W.	6172	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
C.W.	9399	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		40	POWTS dispersal component (soil absorption unit or mound)		65

Comment:

Created On: 04-30-2026 Updated On: 05-19-2026 Review Status: APPROVED