

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN008		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DOW, JIM						Phone # (763)381-4503											
Mailing Address 5320 NORWOOD LN.						Town of LIBERTY GROVE						Fire # (if avail.) 1778					
City N. PLYMOUTH						State ME		Zip Code 55442				Street Address or Road Name and Number HILLSIDE DR.					
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot # Block #					
Door				10247997601		04-29-2026											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
WESLOW WATER SYSTEMS INC				6400				45.2521 °N -87.0844 °W				GPS008					
Address 1710 FLOWING WELLS CT SUAMICO WI 54173				Well Plan Approval #		SE NW		Section Township		Range							
				Approval Date (mm-dd-yyyy)		or Govt Lot # 15		32 N		28 E							
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?											
				0.8													
3. Well serves 1 # of HOME				Hicap Well ?		No											
Private, potable				Hicap Property ?		No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		No											
						Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		140		Yes Rotary - Mud Circulation		No		G		G-GRAVEL/STONES		Surface		5	
6		140		182		No Rotary - Air		Yes		X		X-SAND & CLAY		5		95	
						No Rotary - Air & Foam		No		C		C-CLAY		95		138	
						No Drill-Through Casing Hammer				L		L-LIMESTONE/DOLOMITE		138		182	
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		53 ft. below ground surface		11. Well Is					
6		P.E. A53 18.97# NUCOR WELDED				Surface		140		24 in. above grade							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes					
										Pumping level 100 ft. below surface		Disinfected ? Yes					
										Pumping at 50 GP M for 1 Hrs.		Capped ? Yes					
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed?		No					
NEAT CEMENT GROUT		Surface		140		30 S											
13. Constructor / Supervisory Driller												Lic #		Date Signed			
A.W.												6172		04-30-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
J.S.												9069		04-30-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		85	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED