Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN008

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DOW, JIM	Phone #: (763)381-4503
Mailing Address: 5320 NORWOOD LN.	
City: N. PLYMOUTH	State: ME — Zip Code: 55442
County: Door	Co. Permit #:
Notification #: 10247997601	Completed: 04-29-2026
Well Constructor (Business Name): WESLOW WATER SYSTEMS INC	Lic. #: 6400
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 1710 FLOWING WELLS CT SUAMICO WI 54173	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.8	

1. Well Location

Town of LIBERTY GROVE	Fire # (if avail.): 1778
Street Address or Road Name and Number: HILLSIDE DR.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.2521 °N -87.0844 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 15 — Township: 32 N — Range: 28 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	140
6	140	182

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	G-GRAVEL/STONES	Surface	5
X	X-SAND & CLAY	5	95
C	C-CLAY	95	138
L	L-LIMESTONE/DOLOMITE	138	182

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A53 18.97# NUCOR WELDED	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	140	30 S

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 50 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
A.W.	6172	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
J.S.	9069	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		85	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED