Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN021

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KREBS, RON	Phone #
Mailing Address: 4680 KETTLE MORAINE DR	
City: HARTFORD	State: WI — Zip Code: 53027
County: Washington	Co. Permit #: — Notification #: 10238328502 — Completed: 04-30-2026
Well Constructor (Business Name): SAM'S WELL DRILLING	Lic. #: 370 — Facility ID # (Public Wells):
Address: 150 RANDOLPH STREET, RANDOLPH WI 53956	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of HARTFORD	Fire # (if avail.): 4680
Street Address or Road Name and Number: KETTLE MORAINE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.36048 °N -88.31809 °W	Method Code: GPS008
NW SW or Govt Lot #:	Section: 1 — Township: 10 N — Range: 18 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OUT OF WATER / PIT WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	Z	Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	Surface	35
		Y	C	Y-SAND & GRAVEL C-CLAYEY	35	55
		Y		Y-SAND & GRAVEL	55	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD, BLK, PIPE, 280 WALL, P.E. A53B, WHEATLAND	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	#20 SLOTTED STAINLESS STEEL TELESCOPING SCREEN W/ K-PACKER	73	79

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

46 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

PUMP INSTALLER TO ABANDON WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
JVG	6026	05-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KB	7372	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-01-2026 Updated On: 06-01-2026 Review Status: APPROVED