

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN023		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHMIDT, GREG						Phone # (920)320-9395		1. Well Location				Fire # (if avail.)							
Mailing Address 19412 HWY 151						Town of EATON						19412							
City VALDERS						State WI		Zip Code 54245				Street Address or Road Name and Number							
County Manitowoc						Co. Permit #		Notification # 10223454609		Completed 04-30-2026		Subdivision Name		Lot #		Block #			
Well Constructor (Business Name) HINTZKE WELL DRILLING INC						Lic. # 267		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.0373 °N -87.9569 °W				Method Code GPS008					
Address N5072 HINTZKE RD NEW LONDON WI 54961-9802						Well Plan Approval #		SE SW		Section 11		Township 18 N		Range 21 E					
Hicap Permanent Well #						Common Well #		Specific Capacity 0.4		2. Well Type Replacement				of previous unique well #		constructed in			
3. Well serves 1 # of HOME						Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?				BACTERIA					
Private, potable						Hicap Potable ? No		Construction Type Drilled				Heat Exchange ___ # of drillholes		Heat Exchange ___ # of drillholes					
4. Potential Contamination Sources - ON REVERSE SIDE														5. Drillhole Dimensions and Construction Method		8. Geology			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		78		Yes Rotary - Mud Circulation		No		T		Z		T-TAN/BROWN Z-CLAY & GRAVEL		Surface		60	
6		78		105		No Rotary - Air		Yes		T		L		T-TAN/BROWN L-LIMESTONE/DOLOMITE		60		105	
						No Rotary - Air & Foam		No											
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				20 in. above grade					
6		US WHEATLAND PE 280 WALL A53 WELD				Surface		80		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ? Yes					
										Pumping at 20 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ? Yes									
Method BRADENHEAD										WEBER WELL WILL FILL AND SEAL AT TIME OF HOOK UP									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
NEAT CEMENT GROUT				Surface		78		20 S		WEBER WELL WILL FILL AND SEAL AT TIME OF HOOK UP									
										13. Constructor / Supervisory Driller				Lic #		Date Signed			
										JCH				6935		05-01-2026			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										AMW				8803		05-01-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		80	POWTS dispersal component (soil absorption unit or mound)		120

Comment: WEBER WELL MEASURED SEPTIC AND WILL FILL AND SEAL OLD WELL AND INSTALL PUMP

Created On: 05-01-2026

Updated On: 06-01-2026

Review Status: APPROVED