

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN031		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner BRANDENBURG, ROBERT						Phone # (715)892-3357		1. Well Location				Fire # (if avail.)		
Mailing Address 7970 RAVEN ROAD						Town of LAKE TOMAHAWK						7970		
City LAKE TOMAHAWK						State WI		Zip Code 54539				Street Address or Road Name and Number RAVEN ROAD		
County Oneida		Co. Permit #		Notification # 10247464404		Completed 04-29-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) RHINELANDER WELL DRILLING INC				Lic. # 632		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8137 °N -89.5969 °W			Method Code GPS008	
Address PO BOX 584 3790 COUNTRY DR RHINELANDER WI 54501-0584				Well Plan Approval #		SW NE		Section 3		Township 38 N		Range 7 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT FAILED								
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		96		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ____ in. dia... No Yes Dual Rotary No No Temp. Outer Casing ____ in. dia No Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
T S			T-TAN/BROWN S-SAND			Surface			6					
T C Z			T-TAN/BROWN C-CLAY Z-W/COBBLES/BOULDERS			6			24					
T S C			T-TAN/BROWN S-SAND C-CLAYEY			24			76					
T C			T-TAN/BROWN C-CLAY			76			90					
T S			T-TAN/BROWN S-SAND			90			96					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		A53 GRADE B PLAINEND WELDED WHEATLAND TUBE 19 LBS PER FT				Surface		93						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		STAINLESS STEEL ALLOY 7 SLOT				93		96						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface				3 S						
9. Static Water Level														
48 ft. below ground surface														
10. Pump Test														
Pumping level 86 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift														
11. Well Is														
14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes NOT YET ABANDONED Filled & Sealed Well(s) as needed? Yes NOT YET ABANDONED														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
DGF						8303		05-01-2026						
Drill Rig Operator						Lic or Reg #		Date Signed						
JCE						9286		05-01-2026						

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 05-01-2026

Updated On: 05-27-2026

Review Status: APPROVED