Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN031

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRANDENBURG, ROBERT	Phone #: (715)892-3357
Mailing Address: 7970 RAVEN ROAD	
City: LAKE TOMAHAWK	State: WI — Zip Code: 54539
County: Oneida	Co. Permit #:
Notification #: 10247464404	Completed: 04-29-2026
Well Constructor (Business Name): RHINELANDER WELL DRILLING INC	Lic. #: 632
Facility ID # (Public Wells):	
Address: PO BOX 584 3790 COUNTRY DR RHINELANDER WI 54501-0584	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.4	

1. Well Location

Town of LAKE TOMAHAWK	Fire # (if avail.): 7970
Street Address or Road Name and Number: RAVEN ROAD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8137 °N -89.5969 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 3 — Township: 38 N — Range: 7 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: POINT FAILED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	96

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		T-TAN/BROWN S-SAND	Surface	6
T		C	Z	T-TAN/BROWN C-CLAY Z-W/COBBLES/BOULDERS	6	24
T		S	C	T-TAN/BROWN S-SAND C-CLAYEY	24	76
T		C		T-TAN/BROWN C-CLAY	76	90
T		S		T-TAN/BROWN S-SAND	90	96

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 GRADE B PLAINEND WELDED WHEATLAND TUBE 19 LBS PER FT	Surface	93
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL ALLOY 7 SLOT	93	96

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

9. Static Water Level

48 ft. below ground surface

10. Pump Test

Pumping level 86 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

NOT YET ABANDONED

Filled & Sealed Well(s) as needed? Yes

NOT YET ABANDONED

13. Constructor / Supervisory Driller	Lic #	Date Signed
DGF	8303	05-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JCE	9286	05-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-01-2026 Updated On: 05-27-2026 Review Status: APPROVED