Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN047

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAUMANN KEN	Phone #
Mailing Address: 5331 STARKS SETTLEMENT RD	
City: LAONA	State: WI — Zip Code: 54541
County: Forest	Co. Permit #: — Notification #: 10250245101 — Completed: 05-01-2026
Well Constructor (Business Name): JELINEK WELL DRILLING INC	Lic. #: 6041 — Facility ID # (Public Wells):
Address: 3480 HWY N, RHINELANDER WI 54501	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.4

1. Well Location

Town of LAONA	Fire # (if avail.): 5331
Street Address or Road Name and Number: STARKS SETTLEMENT RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.5434 °N -88.6976 °W	Method Code: GPS008
NE SE or Govt Lot #:	Section: 2 — Township: 35 N — Range: 14 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T A Y	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	Surface	45
T S C	T-TAN/BROWN S-SOFT/LOOSE C-CLAY	45	65
T A S	T-TAN/BROWN A-COARSE S-SAND	65	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97 #/FT WELDED	Surface	76
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON 3'10 SLOT SS	76	79

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	35	2 S

9. Static Water Level

36 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
CG	8207	05-01-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CG	8207	05-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		52	POWTS dispersal component (soil absorption unit or mound)		55

Comment:

Variance ID	Variance or Exception Type	Date	Reason
83590	Landfill Variance	04/14/2026	

Created On: 05-01-2026 Updated On: 10-15-2026 Review Status: APPROVED