Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN056

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BEHNKE, JOSH	Phone #: (920)284-9703
Mailing Address: 1050 VICTORIAN LN	
City: PLOVER	State: WI — Zip Code: 54467
County: Lincoln	Co. Permit #:
Notification #: 10248001701	Completed: 05-01-2026
Well Constructor (Business Name): KOMAREK, THEODORE	Lic. #: 7003
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: TEAM WELL DRILLING LLC N700 STATE HWY 13 OGEMA WI 54459	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Fire # (if avail.):

Town of BRADLEY

Street Address or Road Name and Number: W5840 ROBINSON RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.5548 °N -89.7202 °W

Method Code: GPS008

NW NE or Govt Lot #: | Section: 3 | Township: 35 N | Range: 6 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: POINT FAILING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	19
		S		S-SAND	19	24
G		M		G-GRAY M-SILT	24	55
G		G	U	G-GRAY G-GRAVEL/STONES U-MUDDY OR MURKY	55	70
T		G	U	T-TAN/BROWN G-GRAVEL/STONES U-MUDDY OR MURKY	70	76
T	E	G		T-TAN/BROWN E-CLEAN G-GRAVEL/STONES	76	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	280 ASTM A53B HT A63664 WELD JT WHEATLAND	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 7 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRK	7003	05-02-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TRK		05-02-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		68	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 05-02-2026 Updated On: 10-15-2026 Review Status: APPROVED