

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN056		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BEHNKE, JOSH					Phone # (920)284-9703		1. Well Location				Fire # (if avail.)						
Mailing Address 1050 VICTORIAN LN							Town of BRADLEY										
City PLOVER					State WI		Zip Code 54467										
County Lincoln		Co. Permit #		Notification # 10248001701		Completed 05-01-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KOMAREK, THEODORE					Lic. # 7003		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.5548 °N -89.7202 °W				Method Code GPS008				
Address TEAM WELL DRILLING LLC N700 STATE HWY 13 OGEMA WI 54459					Well Plan Approval #		NW NE Section Township Range or Govt Lot # 3 35 N 6 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT FAILING Construction Type Drilled								
							Approval Date (mm-dd-yyyy)										
Hicap Permanent Well #			Common Well #		Specific Capacity 0												
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ? No												
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		79		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Y Y-SAND & GRAVEL Surface 19 S S-SAND 19 24 G M G-GRAY M-SILT 24 55 G G U G-GRAY G-GRAVEL/STONES U-MUDDY OR MURKY 55 70 T G U T-TAN/BROWN G-GRAVEL/STONES U-MUDDY OR MURKY 70 76 T E G T-TAN/BROWN E-CLEAN G-GRAVEL/STONES 76 79							
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 16 ft. below ground surface				11. Well Is 20 in. above grade			
6.625		280 ASTM A53B HT A63664 WELD JT WHEATLAND				Surface		79		10. Pump Test Pumping level 46 ft. below surface Pumping at 7 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes							
GRANULAR BENTONITE				Surface				1 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
TRK												7003		05-02-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
TRK														05-02-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		68	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 05-02-2026

Updated On: 05-19-2026

Review Status: APPROVED