

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN078		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner NATALIE					Phone #			1. Well Location				Fire # (if avail.)		
Mailing Address N6640PECK STATION ROAD								Town of LAFAYETTE				N6640		
City ELKHORN					State WI		Zip Code 53121		Street Address or Road Name and Number				PECK STATION ROAD	
County Walworth		Co. Permit #		Notification # 10249167103		Completed 05-01-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) SAM'S WELL DRILLING				Lic. # 370		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.73289 °N -88.50805 °W				Method Code GPS008		
Address 150 RANDOLPH STREET RANDOLPH WI 53956				Well Plan Approval #		NE SE		Section 8		Township 3 N		Range 17 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3		2. Well Type Replacement							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? PUMP STUCK / OUT OF WATER Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		117		No Rotary - Mud Circulation				No				
						No Rotary - Air				No				
						No Rotary - Air & Foam				No				
						Yes Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia...				No				
						No Dual Rotary				No				
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
P				P-HARDPAN				Surface		70				
X P G				X- LENSED/STREAKED/LAYERED P-HARDPAN G- W/GRAVEL/STONES				70		111				
E X				E-CLEAN X-SAND & CLAY				111		117				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		STD, BLK, PIPE, 280 WALL, P.E. A53B, KUMAKANG				Surface		113						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		#12 SLOTTED STAINLESS STEEL TELESCOPING SCREEN W/ KPACKER				112		117						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface				1						
9. Static Water Level														
30 ft. below ground surface														
10. Pump Test														
Pumping level 100 ft. below surface														
Pumping at 20 GP M for 1 Hrs.														
Pumping Method ? Airlift														
11. Well Is														
22 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
PUMP INSTALLER TO ABANDON WELL														
13. Constructor / Supervisory Driller				Lic #		Date Signed								
JVG				6026		05-04-2026								
Drill Rig Operator				Lic or Reg #		Date Signed								
KB				7372		05-01-2026								

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 05-04-2026

Updated On: 05-22-2026

Review Status: APPROVED