Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN078

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: NATALIE			Phone #
Mailing Address: N6640PECK STATION ROAD			
City: ELKHORN	State: WI	Zip Code: 53121	
County: Walworth	Co. Permit #:	Notification #: 10249167103	Completed: 05-01-2026

Well Constructor (Business Name): SAM'S WELL DRILLING	Lic. #: 370	Facility ID # (Public Wells):	
Address: 150 RANDOLPH STREET RANDOLPH WI 53956		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of LAFAYETTE

Fire # (if avail.): N6640

Street Address or Road Name and Number: PECK STATION ROAD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.73289 °N -88.50805 °W				Method Code: GPS008
NE SE or Govt Lot #:	Section: 8	Township: 3 N	Range: 17 E	

2. Well Type Replacement
of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?
PUMP STUCK / OUT OF WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	117

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	P			P-HARDPAN	Surface	70
X	P	G		X-LENSED/STREAKED/LAYERED P-HARDPAN G-W/GRAVEL/STONES	70	111
E	X			E-CLEAN X-SAND & CLAY	111	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD, BLK, PIPE, 280 WALL, P.E. A53B, KUMAKANG	Surface	113
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	#12 SLOTTED STAINLESS STEEL TELEASCOPING SCREEN W/ KPACKER	112	117

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes
PUMP INSTALLER TO ABANDON WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
JVG	6026	05-04-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KB	7372	05-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-04-2026 Updated On: 05-22-2026 Review Status: APPROVED