Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN100

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JORDAN THERESA	Phone #
Mailing Address: 1024 23 3/4 ST	
City: CHETEK	State: WI — Zip Code: 54728
County: Barron	Co. Permit #: — Notification #: 10250262001 — Completed: 05-01-2026
Well Constructor (Business Name): AQUA-SERVICE INC	Lic. #: 6083 — Facility ID # (Public Wells):
Address: 1388 24 1/2 ST, CAMERON WI 54822	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 5

1. Well Location

Town of CHETEK	Fire # (if avail.): 1024
Street Address or Road Name and Number: 23 3/4 ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.3539 °N -91.6715 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 12 — Township: 33 N — Range: 11 W

2. Well Type Replacement
of previous unique well # VD021 constructed in
Reason for replaced or reconstructed well ? HIGH NITRATES
Construction Type: Drilled

3. Well serves 1 # of RENTAL HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	S		T-TAN/BROWN V-NON-CAVING S-SAND	Surface	35
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	35	115
T	N	S		T-TAN/BROWN N-FINE S-SAND	115	145
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	145	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 19#/FT ASTM A53B NUCORE WELDED	Surface	157
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	.015 STAINLESS CONT SLOT - STAINLESS STEEL	157	160

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	6562	05-11-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RK	9379	05-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	65	Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 05-05-2026 Updated On: 10-15-2026 Review Status: APPROVED