Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN104

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: AARON MCKINNEY	Phone #
Mailing Address: 45220 US HWY 63	
City: CABLE	State: WI — Zip Code: 54821
County: Bayfield	Co. Permit #: — Notification #: 10239387601 — Completed: 05-05-2026
Well Constructor (Business Name): WAYNE HOLLY WELL DRILLING LLC	Lic. #: 9031 — Facility ID # (Public Wells):
Address: 71385 HOOVER LINE RD, IRON RIVER WI 54847	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

Town of CABLE				Fire # (if avail.): 41595
Street Address or Road Name and Number: CABLE SUNSET RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 46.17957 °N -91.34375 °W				Method Code: GPS008
SE NE or Govt Lot #:	Section: 27	Township: 43 N	Range: 8 W	

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: OLD WELL FAILED
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	72

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	S		T-TAN/BROWN A-COARSE S-SAND	Surface	40
T	A	S	G	T-TAN/BROWN A-COARSE S-SAND G-W/GRAVEL/STONES	40	62
	A	G		A-COARSE G-GRAVEL/STONES	62	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAIN END STEEL, ASTM A53/ASME SA53 SCHED 40 EXLTUBE, WELDED	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL BENTONITE	Surface	70	7 S

9. Static Water Level
59 ft. below ground surface

10. Pump Test
Pumping level 67 ft. below surface
Pumping at 9 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	05-05-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LS	9410	05-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 05-05-2026 Updated On: 07-09-2026 Review Status: APPROVED