

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN104		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner AARON MCKINNEY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 45220 US HWY 63								Town of CABLE				41595			
City CABLE						State WI		Zip Code 54821				Street Address or Road Name and Number CABLE SUNSET RD			
County Bayfield		Co. Permit #		Notification # 10239387601		Completed 05-05-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) WAYNE HOLLY WELL DRILLING LLC				Lic. # 9031		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.17957 °N -91.34375 °W				Method Code GPS008			
Address 71385 HOOVER LINE RD IRON RIVER WI 54847				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 27 43 N 8 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL FAILED							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		Construction Type Drilled									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		72		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				T A S T-TAN/BROWN A-COARSE S-SAND Surface 40 T A S G T-TAN/BROWN A-COARSE S-SAND G-W/GRAVEL/STONES 40 62 A G A-COARSE G-GRAVEL/STONES 62 72					
6. Casing, Liner, Screen												9. Static Water Level 59 ft. below ground surface		11. Well Is 20 in. above grade	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test Pumping level 67 ft. below surface Pumping at 9 GP M for 2 Hrs. Pumping Method ? Test Pump		Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		PLAIN END STEEL, ASTM A53/ASME SA53 SCHED 40 EXLTUBE, WELDED				Surface		72							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material Method BRADENHEAD												12. Notified Owner of need to fill & seal ? Yes			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes							
EZ SEAL BENTONITE		Surface		70		7 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed	
WH												7218		05-05-2026	
Drill Rig Operator												Lic or Reg #		Date Signed	
LS												9410		05-05-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 05-05-2026

Updated On: 07-09-2026

Review Status: APPROVED