Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN140

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PRAHL, TODD	Phone #
Mailing Address: 15245 TELLIER	
City: CRIVITZ	State: WI — Zip Code: 54114
County: Oconto	Co. Permit #: 1 — Notification #: 10248521301 — Completed: 04-30-2026
Well Constructor (Business Name): VAN DE YACHT LEO WELL DRILLING INC	Lic. #: 6097 — Facility ID # (Public Wells)
Address: 1267 LAKEVIEW DR, GREEN BAY WI 54313	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 1

1. Well Location

Town of RIVERVIEW	Fire # (if avail.): 15245
Street Address or Road Name and Number: TELLIER	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 45.2289 °N -88.3683 °W	Method Code: GPS008
NW NW or Govt Lot # — Section: 27 — Township: 32 N — Range: 17 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: SANDPOINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	33

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	M	S-SAND M-SILTY	Surface	28
		S		S-SAND	28	30
		G		G-GRAVEL/STONES	30	33

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END WELDED ASTM A 53B 18 97# PER FT NUCOR PIPE	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BEN SEAL	Surface	33	2 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

TO BE DONE BY PUMP INSTALLER

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLV	6378	05-05-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KZ	7365	05-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	58	Septic or Holding, or POWTS Tank	=	40

Comment: OPEN BOTTOM GRAVEL WELL

Created On: 05-05-2026 Updated On: 05-27-2026 Review Status: APPROVED