

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN143		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner REINL, PHIL						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address N4056 LIBERTY						Town of RIVERVIEW						15227		
City FREEDOM						State WI		Zip Code 54130				Street Address or Road Name and Number TELLIER		
County Oconto		Co. Permit # 1		Notification # 10247170502		Completed 04-29-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) VAN DE YACHT LEO WELL DRILLING INC				Lic. # 6097		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.2285 °N -88.3684 °W			Method Code GPS008	
Address 1267 LAKEVIEW DR GREEN BAY WI 54313				Well Plan Approval #		NW NW		Section 27		Township 32 N		Range 17 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #			Specific Capacity 0.1			2. Well Type Replacement					
Reason for replaced or reconstructed well ? SANDPOINT														
3. Well serves 1 # of HOME						Hicap Well ? No								
Private, potable						Hicap Property ? No								
Heat Exchange ___ # of drillholes						Hicap Potable ? No								
						Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		261		No Rotary - Mud Circulation			No					
						No Rotary - Air			Yes					
						No Rotary - Air & Foam			No					
						Yes Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia...			No					
						No Dual Rotary			No					
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
S			S-SAND			Surface			28					
Z M			Z-CLAY & GRAVEL M-SILTY			28			45					
G M			G-GRAVEL/STONES M-SILTY			45			48					
Q			Q-GRANITE			48			261					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		NEW BLACK STEEL PLAIN END WELDED ASTM A 53B 18 97# PER FT NUCOR PIPE				Surface		48						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
BEN SEAL				Surface		48		2 S						
9. Static Water Level														
10 ft. below ground surface														
10. Pump Test														
Pumping level 140 ft. below surface														
Pumping at 10 GP M for 2 Hrs.														
Pumping Method ? Airlift														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
TO BE DONE BY PUMP INSTALLER														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
TLV				6378				05-05-2026						
Drill Rig Operator														
Lic or Reg #				Date Signed										
KZ				7365				05-05-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	90	Septic or Holding, or POWTS Tank	=	60

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	05/01/2026	10 GPM

Created On: 05-05-2026

Updated On: 05-27-2026

Review Status: APPROVED