Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN163

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SOPIK, RON	Phone #
Mailing Address: N10563 19TH AVE	
City: NECEDAH	State: WI Zip Code: 54646
County: Juneau	Co. Permit #:
Notification #: 10256222301	Completed: 05-04-2026
Well Constructor (Business Name): HEZPAZ ENTERPRIZES	Lic. #: 8094
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 3898 5TH DR WISCONSIN DELLS WI 53965	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.1	

1. Well Location

Town of NECEDAH	Fire # (if avail.): N10563
Street Address or Road Name and Number: 19TH AVE	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.02663 °N -90.02166 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 16 Township: 18 N Range: 4 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: SAND POINT PLUGGED

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	41
1.25	41	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	S	S		Y-YELLOW S-SOFT/LOOSE S-SAND	Surface	12
T	M	Y		T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL	12	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND A53 SCH 40 T&C	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	SSCSWR #10 SLOT W/ KPACKER	41	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	41	0.5 S

9. Static Water Level

29 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 7.5 GP M for 2.5 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HZ	3851	05-14-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		44	POWTS dispersal component (soil absorption unit or mound)		61

Comment:

Created On: 05-06-2026 Updated On: 10-15-2026 Review Status: APPROVED