

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN163		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SOPIK, RON					Phone #			1. Well Location Fire # (if avail.) Town of NECEDAH N10563 Street Address or Road Name and Number 19TH AVE			
Mailing Address N10563 19TH AVE											
City NECEDAH			State WI		Zip Code 54646		Subdivision Name Lot # Block #				
County Juneau		Co. Permit #		Notification # 10256222301		Completed 05-04-2026					
Well Constructor (Business Name) HEZPAZ ENTERPRIZES				Lic. # 8094		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.02663 °N -90.02166 °W	
Address 3898 5TH DR WISCONSIN DELLS WI 53965				Well Plan Approval #		SW SE		Section 16		Township 18 N	
				Approval Date (mm-dd-yyyy)		Range 4 E					
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SAND POINT PLUGGED Construction Type Jetted				
Heat Exchange ___ # of drillholes					Hicap Well ? No						
Private, potable					Hicap Property ? No						
Hicap Potable ? No											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes											
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...	
2		Surface		41		No Rotary - Mud Circulation		No		Y S S Y-YELLOW S-SOFT/LOOSE S-SAND	
1.25		41		44		No Rotary - Air		No		T M Y T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL	
						No Rotary - Air & Foam		No			
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
2		WHEATLAND A53 SCH 40 T&C				Surface		41			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
1.25		SSCSWR #10 SLOT W/ KPACKER				41		44			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface		41		0.5 S			
9. Static Water Level 29 ft. below ground surface											
10. Pump Test Pumping level 36 ft. below surface Pumping at 7.5 GP M for 2.5 Hrs. Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
HZ						3851		05-14-2026			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		44	POWTS dispersal component (soil absorption unit or mound)		61

Comment:

Created On: 05-06-2026

Updated On: 06-01-2026

Review Status: APPROVED