

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN195		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KUCZMARSKI, JESSE AND CHANTEL						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 6882 HOLIDAY HAVEN LN						Town of THREE LAKES						6882			
City THREE LAKES						State WI		Zip Code 54562				Street Address or Road Name and Number HOLIDAY HAVEN LN			
County Oneida		Co. Permit #		Notification # 10247048401		Completed 05-01-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) HEDBERG W D/ECS HOLDINGS LLC				Lic. # 6416		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.79051 °N -89.07956 °W				Method Code GPS008	
Address PO BOX 1206 EAGLE RIVER WI 54521				Well Plan Approval #				SW NE		Section 11		Township 38 N		Range 11 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 2.6				2. Well Type Replacement of previous unique well # ZA904 constructed in 2018					
Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No				Reason for replaced or reconstructed well ? ADDITION TO DWELLING				Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		58.5		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		Y		T-TAN/BROWN Y-SAND & GRAVEL				Surface				15			
G		M	G	G-GRAY M-SILT G-W/GRAVEL/STONES				15				38			
G		K	M	G-GRAY K-COBBLERS/BOULDERS M-SILTY				38				48			
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL				48				58.5			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NOVATUBE ASTM A53B 18.97# WELDED				Surface		58.5							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		30		0.75 S							
9. Static Water Level															
6.5 ft. below ground surface															
10. Pump Test															
Pumping level 13 ft. below surface															
Pumping at 17 GP M for 4 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
ES				Lic # 6673		Date Signed 05-01-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Septic or Holding, or POWTS Tank		85

Comment:

Created On: 05-06-2026

Updated On: 05-27-2026

Review Status: APPROVED