Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN195

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KUCZMARSKI, JESSE AND CHANTEL	Phone #
Mailing Address: 6882 HOLIDAY HAVEN LN	
City: THREE LAKES	State: WI — Zip Code: 54562
County: Oneida	Co. Permit #: — Notification #: 10247048401 — Completed: 05-01-2026

1. Well Location

Town of THREE LAKES	Fire # (if avail.): 6882
Street Address or Road Name and Number: HOLIDAY HAVEN LN	
Subdivision Name: — Lot #: — Block #: —	

Well Constructor (Business Name): HEDBERG W D/ECS HOLDINGS LLC	Lic. #: 6416	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 45.79051 °N -89.07956 °W — Method Code: GPS008
		Well Plan Approval #:	SW NE or Govt Lot #: — Section: 11 — Township: 38 N — Range: 11 E
Address: PO BOX 1206 EAGLE RIVER WI 54521		Approval Date (mm-dd-yyyy):	**2. Well Type** Replacement of previous unique well #: ZA904 constructed in: 2018
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.6	Reason for replaced or reconstructed well ?: ADDITION TO DWELLING
3. Well serves 1 # of HOME Private,potable Heat Exchange____# of drillholes		Hicap Well ? No Hicap Property ? No Hicap Potable ? No	Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	15
G		M	G	G-GRAY M-SILT G-W/GRAVEL/STONES	15	38
G		K	M	G-GRAY K-COBBLES/BOULDERS M-SILTY	38	48
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	48	58.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NOVATUBE ASTM A53B 18.97# WELDED	Surface	58.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	30	0.75 S

9. Static Water Level
6.5 ft. below ground surface

10. Pump Test
Pumping level 13 ft. below surface
Pumping at 17 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ES	6673	05-01-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Septic or Holding, or POWTS Tank		85

Comment:

Created On: 05-06-2026 Updated On: 05-27-2026 Review Status: APPROVED