Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN233

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SUNDSTROM, TOM	Phone #
Mailing Address: 1965 CY WILLIAMS RD	
City: THREE LAKES	State: WI — Zip Code: 54562
County: Oneida	Co. Permit #: — Notification #: 10246411301 — Completed: 05-05-2026
Well Constructor (Business Name): HEDBERG W D/ECS HOLDINGS LLC	Lic. #: 6416 — Facility ID # (Public Wells):
Address: PO BOX 1206 EAGLE RIVER WI 54521	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.4

1. Well Location

Town of THREE LAKES	Fire # (if avail.): 1965
Street Address or Road Name and Number: CY WILLIAMS RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.82439 °N -89.17995 °W	Method Code: GPS008

SE	NE	Section	Township	Range
or Govt Lot #		36	39 N	10 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: POINT WELL FAILING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	S		T-TAN/BROWN A-COARSE S-SAND	Surface	29
	N	X		N-FINE X-SAND & CLAY	29	42
T	N	S		T-TAN/BROWN N-FINE S-SAND	42	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NOVATUBE ASTM A53B 18.97# WELDED	Surface	55
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5.5	SS BIGFOOT 10 SLOT	55	58

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	25	1 S

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 17 GP M for 0.5 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ES	6673	05-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 05-07-2026 Updated On: 06-01-2026 Review Status: APPROVED