

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN278		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner LEMANCICK, JIM					Phone #		1. Well Location Fire # (if avail.) 1605					
Mailing Address W2430 VALLEYWOOD LN												
City APPLETON			State WI		Zip Code 54915		Town of ARBOR VITAE Street Address or Road Name and Number PROPWASH BAY RD					
County Vilas		Co. Permit #		Notification # 10093507801		Completed 05-07-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) D&M WATERWORKS LLC				Lic. # 9148		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9283 °N -89.7393 °W			Method Code GPS008	
Address DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 28 40 N 6 E		2. Well Type Replacement of previous unique well # MN158 constructed in 1998 Reason for replaced or reconstructed well ? LOW VOLUME Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 1.7							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
9		Surface		49		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)				
Y			Y-SAND & GRAVEL			Surface		30				
A S			A-COARSE S-SAND			30		49				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)		To (ft.)					
5		SDR21 PVC 200 PSI, ASTM D2241-F480, CRESLINE, GLUED			Surface		46					
Dia. (in.)		Screen type, material & slot size			From (ft.)		To (ft.)					
4		ALLOY SS 10 SLOT			46		49					
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement					
BENTONITE GROUT, 20% SOLIDS, 9.8 LBS			Surface		39		4 S					
#40 GRAVEL PACK, RED FLINT			39		49		10 S					
9. Static Water Level 17 ft. below ground surface												
10. Pump Test Pumping level 23 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ? Test Pump												
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes												
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller TF			Lic # 8520		Date Signed 05-07-2026							
Drill Rig Operator CM			Lic or Reg # 8443		Date Signed 05-07-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	60	Septic or Holding, or POWTS Tank	=	40

Comment:

Created On: 05-09-2026

Updated On: 06-01-2026

Review Status: APPROVED