Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN296

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PLYER, FRANK	Phone #: (715)657-0137
Mailing Address: N10012 DARDIS LAKE LN	
City: PHILLIPS	State: WI — Zip Code: 54555
County: Price	Co. Permit #: — Notification #: 10250222401 — Completed: 05-08-2026
Well Constructor (Business Name): KOMAREK, THEODORE	Lic. #: 7003 — Facility ID # (Public Wells):
Address: TEAM WELL DRILLING LLC N700 STATE HWY 13, OGEMA WI 54459	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location
Town of WORCESTER
Fire # (if avail.):
Street Address or Road Name and Number: N10012 DARDIS LAKE LN
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7385 °N -90.3228 °W — Method Code: GPS008
NE NW or Govt Lot #: — Section: 35 — Township: 38 N — Range: 1 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: WELL FAILING
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	62

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	6
		M		M-SILT	6	36
		X		X-SAND & CLAY	36	47
		Z	U	Z-CLAY & GRAVEL U-MUDDY OR MURKY	47	59
		S	U	S-SAND U-MUDDY OR MURKY	59	60
		G	U	G-GRAVEL/STONES U-MUDDY OR MURKY	60	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	280 ASTM A53B HT A63664 WELD JT WHEATLAND	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
29 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 3 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
19 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes
WILL FILL AND SEAL WHEN WATERSYSTEM IS INSTALLED

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRK	7003	05-11-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TRK		05-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 05-11-2026 Updated On: 10-15-2026 Review Status: APPROVED