Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN309

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HANDROW, LISA	Phone #: (920)253-9071
Mailing Address: 108 WHISLE ST APT # 108	
City: MARSHAL	State: WI — Zip Code: 53559
County: Vilas	Co. Permit #: — Notification #: 10162192001 — Completed: 05-11-2026
Well Constructor (Business Name): WRANIK, THOMAS F	Lic. #: 70 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: PO BOX 1266 W620 W PINE ST EAGLE RIVER WI 54521-1266	
Hicap Permanent Well #: — Common Well # — Specific Capacity: 3	

1. Well Location

Town of PHELPS	Fire # (if avail.): 1988
Street Address or Road Name and Number: ST. LOUIS ROAD	
Subdivision Name: — Lot #: — Block #: —	
Latitude / Longitude in Decimal Degree (DD): 46.04133 °N -89.0627 °W	Method Code: SCR002
SW SE or Govt Lot #: — Section: 12 — Township: 41 N — Range: 11 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: LOW VOLUME

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	23
		Y	C	Y-SAND & GRAVEL C-CLAYEY	23	35
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	35	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53BWELDED WHEATLAND 18.97LB SEC 40X20	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	TEL, JOHNSON SS #10	37	40

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	26	2.5 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	70	05-11-2026
Drill Rig Operator	Lic or Reg #	Date Signed
PN	7304	05-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	80	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-11-2026 Updated On: 10-15-2026 Review Status: APPROVED