

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN309		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HANDROW, LISA						Phone # (920)253-9071		1. Well Location				Fire # (if avail.)					
Mailing Address 108 WHISLE ST APT # 108						Town of PHELPS						1988					
City MARSHAL						State WI		Zip Code 53559				Street Address or Road Name and Number					
County Vilas						Co. Permit #		Notification # 10162192001		Completed 05-11-2026		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) WRANIK, THOMAS F						Lic. # 70		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.04133 °N -89.0627 °W				Method Code SCR002			
Address PO BOX 1266 W620 W PINE ST EAGLE RIVER WI 54521-1266						Well Plan Approval #		SW SE		Section 12		Township 41 N		Range 11 E			
								or Govt Lot #									
Approval Date (mm-dd-yyyy)						2. Well Type Replacement											
Hicap Permanent Well #						Common Well #		Specific Capacity 0		of previous unique well #				constructed in			
Reason for replaced or reconstructed well ?						LOW VOLUME											
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled									
Private, potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		40		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)											
Y		Y-SAND & GRAVEL		Surface		23											
Y C		Y-SAND & GRAVEL C-CLAYEY		23		35											
T Y		T-TAN/BROWN Y-SAND & GRAVEL		35		40											
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		A53BWELDED WHEATLAND 18.97LB SEC 40X20				Surface		37									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		TEL, JOHNSON SS #10				37		40									
7. Grout or Other Sealing Material																	
Method MOUNDED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE				Surface		26		2.5 S									
9. Static Water Level																	
26 ft. below ground surface																	
10. Pump Test																	
Pumping level 30 ft. below surface																	
Pumping at 12 GP M for 2 Hrs.																	
Pumping Method ? Test Pump																	
11. Well Is																	
12 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ? Yes																	
Filled & Sealed Well(s) as needed? Yes																	
13. Constructor / Supervisory Driller																	
Lic #				Date Signed													
TW				70				05-11-2026									
Drill Rig Operator				Lic or Reg #				Date Signed									
PN				7304				05-11-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	80	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-11-2026

Updated On: 06-01-2026

Review Status: APPROVED