Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN324

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SIEFERT, STEVE	Phone #: (715)493-0551
Mailing Address: 6433 TOM DOYLE LAKE ROAD	
City: RHINELANDER	State: WI — Zip Code: 54501
County: Oneida	Co. Permit #:
Notification #: 10259917601	Completed: 05-11-2026
Well Constructor (Business Name): RHINELANDER WELL DRILLING INC	Lic. #: 632
Facility ID # (Public Wells):	
Address: PO BOX 584 3790 COUNTRY DR RHINELANDER WI 54501-0584	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.9	

1. Well Location

Town of NEWBOLD	Fire # (if avail.): 6433
Street Address or Road Name and Number: TOM DOYLE LAKE ROAD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7613 °N -89.4901 °W	Method Code: GPS008
SE SE or Govt Lot #	Section: 21 — Township: 38 N — Range: 8 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: POINT FAILED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S	T-TAN/BROWN S-SAND	Surface	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 GRADE B PLAINEND WELDED WHEATLAND TUBE 19 LBS PER FT	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL ALLOY 7 SLOT	35	38

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DGF	8303	05-12-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DGF	8303	05-12-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-11-2026 Updated On: 06-01-2026 Review Status: APPROVED