Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN329

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HURTGEN, DUSTY			Phone #
Mailing Address: 3823 CUMMINGS AVENUE			
City: EAU CLAIRE	State: WI	Zip Code: 54701	
County: Washburn	Co. Permit #:	Notification #: 10233654502	Completed: 05-04-2026

Well Constructor (Business Name): JEREMY BEECROFT WELL DRILLING	Lic. #: 6457	Facility ID # (Public Wells):	
Address: W7414 MILLER RD SPOONER WI 54801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.8	

1. Well Location

Town of SPOONER

Fire # (if avail.): W5654

Street Address or Road Name and Number: W5654 PEACH TREE LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8293 °N	-91.8232 °W			GPS008

SW SW or Govt Lot #	Section	Township	Range
	26	39 N	12 W

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: SLOW POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17PVC CASING WELDED ASTM F480	Surface	55
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	12 SLOT SS SCREEN	55	60

7. Grout or Other Sealing Material

Method: TREMIE PIPE- PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	50	4 S

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 100 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	05-11-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF	8979	05-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		40	POWTS dispersal component (soil absorption unit or mound)		52

Comment:

Created On: 05-11-2026 Updated On: 10-15-2026 Review Status: APPROVED