

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN329		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner HURTGEN, DUSTY					Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 3823 CUMMINGS AVENUE							Town of SPOONER				W5654	
City EAU CLAIRE					State WI		Zip Code 54701				Street Address or Road Name and Number W5654 PEACH TREE LANE	
County Washburn		Co. Permit #		Notification # 10233654502		Completed 05-04-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) JEREMY BEECROFT WELL DRILLING				Lic. # 6457		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8293 °N -91.8232 °W			Method Code GPS008	
Address W7414 MILLER RD SPOONER WI 54801				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 26 39 N 12 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SLOW POINT				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0		Construction Type Drilled					
3. Well serves 1 # of HOME					Hicap Well ? No							
Private, potable					Hicap Property ? No							
Heat Exchange ___ # of drillholes					Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
8.75		Surface		60		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)			
Y			Y-SAND & GRAVEL			Surface			60			
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
5		SDR17PVC CASING WELDED ASTM F480				Surface		55				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
5		12 SLOT SS SCREEN				55		60				
7. Grout or Other Sealing Material												
Method TREMIE PIPE- PUMPED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				
EZ SEAL				Surface		50		4 S				
9. Static Water Level												
14 ft. below ground surface												
10. Pump Test												
Pumping level 40 ft. below surface												
Pumping at 100 GP M for 1 Hrs.												
Pumping Method ? Airlift												
11. Well Is												
18 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ? Yes												
Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller												
Lic #				Date Signed								
JB				6457				05-11-2026				
Drill Rig Operator				Lic or Reg #				Date Signed				
JF				8979				05-11-2026				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		40	POWTS dispersal component (soil absorption unit or mound)		52

Comment:

Created On: 05-11-2026

Updated On: 06-01-2026

Review Status: APPROVED