Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN330

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MARSCHALL TODD	Phone #
Mailing Address: 5074 192ND ST W	
City: FARMINGTON	State: MN — Zip Code: 55024
County: Polk	Co. Permit #: — Notification #: 10263201801 — Completed: 05-11-2026
Well Constructor (Business Name): AQUA-SERVICE INC	Lic. #: 6083 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: 1388 24 1/2 ST, CAMERON WI 54822	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 15	

1. Well Location

Town of BEAVER	Fire # (if avail.): 180
Street Address or Road Name and Number: 154TH AVE	
Subdivision Name: — Lot #: — Block #: —	
Latitude / Longitude in Decimal Degree (DD): 45.4308 °N -92.1946 °W	Method Code: SCR002

NW	SW	Section	Township	Range
or Govt Lot #		14	34 N	15 W

2. Well Type Replacement
of previous unique well # — constructed in —
Reason for replaced or reconstructed well ? LOW PRODUCTION
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	Y		T-TAN/BROWN V-NON-CAVING Y-SAND & GRAVEL	Surface	33
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	33	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 19#/FT ASTM A53B NUCORE WELDED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	.015 STAINLESS CONT SLOT - STAINLESS STEEL	57	60

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 29 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	6562	05-11-2026
Drill Rig Operator	Lic or Reg #	Date Signed
PH	7429	05-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	80	Septic or Holding, or POWTS Tank	=	26

Comment:

Created On: 05-11-2026 Updated On: 10-15-2026 Review Status: APPROVED