

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN346		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner TIM MORRISON					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 20430 OTERO AVE							Town of JACKSON				27208		
City HASTINGS					State MN		Zip Code 55033				Street Address or Road Name and Number CORBIN ROAD		
County Burnett		Co. Permit #		Notification # 10258487301		Completed 05-11-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) D M B DRILLING CO INC				Lic. # 6749		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9006 °N -92.18 °W				Method Code SCR002	
Address W8760 CTY HWY J SHELL LAKE WI 54871				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 6 2 39 N 15 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 3.8									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
8.75		Surface		46		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T S S T-TAN/BROWN S-SOFT/LOOSE S-SAND Surface 10 R X X R-RED X-LENSED/STREAKED/LAYERED X-SAND & CLAY 10 25 T W Y T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL 25 46			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
5		CRESTLINE PVC SDR 21 SOLVENT JOINT				Surface		42		18 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
4		ATTCECHED STAINLESS STEEL 18 SLOT				42		46		18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
EZ SEAL		Surface		40		4 S		Filled & Sealed Well(s) as needed? No					
RED FLINT # 40		40		46		6 S							
13. Constructor / Supervisory Driller													
DMB		6242		05-12-2026		Lic #		Date Signed					
Drill Rig Operator		Lic or Reg #		Date Signed		SRB		9030		05-12-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50

Comment:

Created On: 05-12-2026

Updated On: 06-01-2026

Review Status: APPROVED