Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN346

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TIM MORRISON			Phone #
Mailing Address: 20430 OTERO AVE			
City: HASTINGS	State: MN	Zip Code: 55033	
County: Burnett	Co. Permit #:	Notification #: 10258487301	Completed: 05-11-2026

Well Constructor (Business Name): D M B DRILLING CO INC	Lic. #: 6749	Facility ID # (Public Wells):
Address: W8760 CTY HWY J SHELL LAKE WI 54871		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.8

1. Well Location

Fire # (if avail.): 27208				
Town of JACKSON				
Street Address or Road Name and Number: CORBIN ROAD				
Subdivision Name:	Lot #:	Block #:		
Latitude / Longitude in Decimal Degree (DD): 45.9006 °N -92.18 °W	Method Code: SCR002			
NE or Govt Lot #: NE 6	Section: 2	Township: 39 N	Range: 15 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	10
R	X	X		R-RED X-LENSED/STREAKED/LAYERED X-SAND & CLAY	10	25
T	W	Y		T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL	25	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	CRESTLINE PVC SDR 21 SOLVENT JOINT	Surface	42
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	ATTCHECHED STAINLESS STEEL 18 SLOT	42	46

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	40	4 S
RED FLINT # 40	40	46	6 S

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 22 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DMB	6242	05-12-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SRB	9030	05-12-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50

Comment:

Created On: 05-12-2026 Updated On: 06-01-2026 Review Status: APPROVED