Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN351

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PERENICK, ROGER	Phone #
Mailing Address: W4784 S PEARL LAKE RD	
City: REDGRANITE	State: WI — Zip Code: 54970

County	Co. Permit #	Notification #	Completed
Waushara		10261248201	05-11-2026

Well Constructor (Business Name): WELLS BY WELCH - BENTLEY WD LLC	Lic #: 7500
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 9403 TRI COUNTY RD FREMONT WI 54940	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.5	

1. Well Location

Town of LEON				Fire # (if avail.): W4784
Street Address or Road Name and Number: S PEARL LAKE RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.0883 °N -89.1217 °W				Method Code: OTH001
NE SW or Govt Lot #	Section: 30	Township: 19 N	Range: 12 E	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL NOT UP TO CODE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	98

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	35
		G		G-GRAVEL/STONES	35	65
		Z	S	Z-CLAY & GRAVEL S-SANDY	65	77
		Y		Y-SAND & GRAVEL	77	98

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, P/E, WELDED, NUCOR, .280 WALL, ASTMA53B.	Surface	92
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S. S. #12	92	98

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BETONITE	Surface	91	9 S
GRAVEL PACK #20	91	98	11 S

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface
Pumping at 10 GP M for 48 Hrs.
Pumping Method ? Other

11. Well Is

24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB	7036	05-12-2026
Drill Rig Operator	Lic or Reg #	Date Signed
IA	9217	05-12-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Created On: 05-12-2026 Updated On: 10-15-2026 Review Status: APPROVED