

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN351		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner PERENICK, ROGER						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address W4784 S PEARL LAKE RD						Town of LEON						W4784							
City REDGRANITE						State WI		Zip Code 54970				Street Address or Road Name and Number S PEARL LAKE RD							
County Waushara		Co. Permit #		Notification # 10261248201		Completed 05-11-2026		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) WELLS BY WELCH - BENTLEY WD LLC				Lic. # 7500		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0883 °N -89.1217 °W				Method Code OTH001					
Address 9403 TRI COUNTY RD FREMONT WI 54940				Well Plan Approval #		NE SW		Section 30		Township 19 N		Range 12 E							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.3				2. Well Type Replacement							
Hicap Property ? No				Hicap Potable ? No		Reason for replaced or reconstructed well ? OLD WELL NOT UP TO CODE				Construction Type Drilled									
3. Well serves 1 # of HOME				Private, potable		Heat Exchange ___ # of drillholes				4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		98		Yes Rotary - Mud Circulation				No		Y		Y-SAND & GRAVEL		Surface		35	
						No Rotary - Air				No		G		G-GRAVEL/STONES		35		65	
						No Rotary - Air & Foam				No		Z S		Z-CLAY & GRAVEL S-SANDY		65		77	
						No Drill-Through Casing Hammer						Y		Y-SAND & GRAVEL		77		98	
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				24 in. above grade					
6		STEEL, P/E, WELDED, NUCOR, .280 WALL, ASTMA53B.				Surface		92		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
6		S. S. #12				92		98		Pumping at 10 GP M for 48 Hrs.				Capped ? Yes					
										Pumping Method ? Other									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method TREMIE PIPE - PUMPED												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed	
HIGH SOLIDS BETONITE				Surface		91		9 S				PB				7036		05-12-2026	
GRAVEL PACK #20				91		98		11 S				Drill Rig Operator				Lic or Reg #		Date Signed	
												IA				9217		05-12-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Created On: 05-12-2026

Updated On: 06-01-2026

Review Status: APPROVED