

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN383		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner DOMAGLA, BRAD						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 3053 130TH ST						Town of BLAINE																	
City FREDERIC						State WI		Zip Code 54837															
County Burnett		Co. Permit #		Notification # 10255913602		Completed 05-07-2026		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) CHELL WELL DRILLING				Lic. # 22		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.07041 °N -92.2293 °W				Method Code SCR002									
Address 1471 345TH AVE FREDERIC WI 54837				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 34 42 N 15 W				2. Well Type Replacement													
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity 2		Reason for replaced or reconstructed well ? DRY POINT				Construction Type Drilled													
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		212		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>Yes</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						S		S-SAND		Surface		45					
												Z		Z-CLAY & GRAVEL		45		50					
												P Z		P-HARDPAN Z-W/COBBLES/BOULDERS		50		170					
												Z		Z-CLAY & GRAVEL		170		211					
												B		B-BASALT OR TRAP ROCK		211		212					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		65 ft. below ground surface				18 in. above grade									
6		STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD				Surface		211		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 100 ft. below surface				Disinfected ? Yes									
0		NONE				0		0		Pumping at 70 GP M for 1 Hrs.				Capped ? Yes									
										Pumping Method ? Airlift													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes									
Method MOUNDED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes													
GRANULAR BENTONITE				Surface																			
13. Constructor / Supervisory Driller								Lic #		Date Signed													
DJC								6846		05-12-2026													
Drill Rig Operator								Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	70	POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Created On: 05-12-2026

Updated On: 06-01-2026

Review Status: APPROVED