Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN383

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DOMAGLA, BRAD			Phone #
Mailing Address: 3053 130TH ST			
City: FREDERIC	State: WI	Zip Code: 54837	
County: Burnett	Co. Permit #:	Notification #: 10255913602	Completed: 05-07-2026

Well Constructor (Business Name): CHELL WELL DRILLING	Lic. #: 22	Facility ID # (Public Wells):	
Address: 1471 345TH AVE FREDERIC WI 54837		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2	

1. Well Location

Town of BLAINE

Fire # (if avail.)

Street Address or Road Name and Number: 4834 SPRINGBROOK TR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
46.07041 °N	-92.2293 °W			SCR002
SE SW or Govt Lot #	Section: 34	Township: 42 N	Range: 15 W	

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: DRY POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	212

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	Yes
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	45
		Z		Z-CLAY & GRAVEL	45	50
		P	Z	P-HARDPAN Z-W/COBBLES/BOULDERS	50	170
		Z		Z-CLAY & GRAVEL	170	211
		B		B-BASALT OR TRAP ROCK	211	212

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD	Surface	211
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
0	NONE	0	0

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

65 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 70 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJC	6846	05-12-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	70	POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Created On: 05-12-2026 Updated On: 06-01-2026 Review Status: APPROVED