

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN423		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KLECKNER LIVING TR, KEVIN & STEPHANIE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 5833 GRASSLAND TERR						Town of SUN PRAIRIE						2608					
City MARSHALL						State WI		Zip Code 53559				Street Address or Road Name and Number					
2608 COUNTY HIGHWAY T						Subdivision Name				Lot #		Block #					
County Dane		Co. Permit # 00040		Notification # 10263186701		Completed 05-12-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) WEBSTER & SONS WELL DRILLING, LLC						Lic. # 9242		Facility ID # (Public Wells)				43.1433 °N -89.2053 °W		GPS008			
Address 415 N. MAIN STREET POYNETTE WI 53955						Well Plan Approval #		NW SW		Section 21		Township 8 N		Range 11 E			
						Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 0		2. Well Type Replacement									
Reason for replaced or reconstructed well ?						TORE DOWN OLD BUILDINDS. DRILLED NEXT TO NEW											
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled									
Private, potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		162		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				F C F-FILL C-CLAYEY Z Z-CLAY & GRAVEL Z S Z-CLAY & GRAVEL S-SANDY G C G-GRAVEL/STONES C-CLAYEY Z Z-CLAY & GRAVEL Y M Y-SAND & GRAVEL M-SILTY S N S-SOFT/LOOSE N-SANDSTONE H N H-HARD/FIRM N-SANDSTONE H L H-HARD/FIRM L-LIMESTONE/DOLOMITE		Surface 6 28 45 54 90 111 117 153 162					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		WHEATLAND A53B PE .280 WALL				Surface		117									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method MOUNDED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE				Surface		117		2 S									
8. Geology																	

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 18 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Yes

ABANDONED WHEN WELL WAS BEING DRILLED

Filled & Sealed Well(s) as needed?

Yes

ABANDONED WHEN WELL WAS BEING DRILLED

13. Constructor / Supervisory Driller

Lic #

Date Signed

RW

6890

05-14-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Sewer - Building Sanitary	>	60
Animal Barn or Barn Pen	>	200	Silo/Storage Tube	>	200
Building Drain - Sanitary	>	15	Septic or Holding, or POWTS Tank	>	90

Comment:

Created On: 05-14-2026

Updated On: 06-01-2026

Review Status: APPROVED