Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN432

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JAESPERSON, TAMARA	Phone #: (715)319-1368
Mailing Address: 2165 RANKINSON RD	
City: BRULE	State: WI — Zip Code: 54820
County: Bayfield	Co. Permit #:
Notification #: 10264088601	Completed: 05-13-2026
Well Constructor (Business Name): WAYNE HOLLY WELL DRILLING LLC	Lic. #: 9031
Facility ID # (Public Wells):	
Address: 71385 HOOVER LINE RD, IRON RIVER WI 54847	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of OULU	Fire # (if avail.): 2165
Street Address or Road Name and Number: RANKINSON RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.61092 °N -91.53024 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 29 — Township: 48 N — Range: 9 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD WELL FAILED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	88

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		S	P	R-RED S-SAND P-W/HARDPAN	Surface	20
T	A	S		T-TAN/BROWN A-COARSE S-SAND	20	80
U	B	S	B	U-BLUE B-BROKEN S-SAND B-BASALT OR TRAP ROCK	80	88

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR 17 PVC, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT STAINLESS STEEL FLATBOTTOM	84	88

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	80	8 S

9. Static Water Level

70 ft. below ground surface

10. Pump Test

Pumping level 78 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH	8983	05-14-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LS	9410	05-14-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 05-14-2026 Updated On: 07-09-2026 Review Status: APPROVED