

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN432		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner JAESPERSON, TAMARA					Phone # (715)319-1368		1. Well Location				Fire # (if avail.)		
Mailing Address 2165 RANKINSON RD							Town of OULU				2165		
City BRULE					State WI		Zip Code 54820				Street Address or Road Name and Number RANKINSON RD		
County Bayfield		Co. Permit #		Notification # 10264088601		Completed 05-13-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) WAYNE HOLLY WELL DRILLING LLC				Lic. # 9031		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.61092 °N -91.53024 °W				Method Code SCR002	
Address 71385 HOOVER LINE RD IRON RIVER WI 54847				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 29 48 N 9 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL FAILED					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3				Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
9		Surface		88		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) R S P R-RED S-SAND P-W/HARDPAN Surface 20 T A S T-TAN/BROWN A-COARSE S-SAND 20 80 U B S B U-BLUE B-BROKEN S-SAND B-BASALT OR TRAP ROCK 80 88			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
5		SDR 17 PVC, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED				Surface		84		70 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
4		10 SLOT STAINLESS STEEL FLATBOTTOM				84		88		20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes					
GRANULAR BENTONITE		Surface		80		8 S		Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller													
DH		8983		05-14-2026		13. Constructor / Supervisory Driller		Lic #		Date Signed			
Drill Rig Operator		LS		9410		05-14-2026		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 05-14-2026

Updated On: 07-09-2026

Review Status: APPROVED